

Certificate

Registration No.: PV 60077808

Page 2

Report No.: 21183157.002

License Holder:
Philadelphia Solar Ltd. Co.
Air Fright Road
Al Qastal Industrial Area 2
11814/Amman
Jordan

Product:
PV Module
Type:
with 6" poly cells
PS-P60-xxx (xxx = 245-250 in steps of 5, 60 cells)
xxx represent output power in Wp

Manufacturing plant:
Philadelphia Solar Ltd. Co.
Air Fright Road
Al Qastal Industrial Area 2
11814/Amman
Jordan

Basis:

IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

Factory Inspection
To document the consistent quality of the product factory inspections are performed periodically.



www.tuv.com
ID 0000037007

Remarks:

- Valid in conjunction with TÜV Rheinland certificate based on IEC EN 61215.
- The above listed PV modules fulfil the requirements of Application **Class A** (Class II acc. to IEC 61140). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The above listed PV modules fulfil the requirements of **fire rating class C**.
- Extension to higher power range.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 18 July 2017.

Cologne, 8 July 2013

Certification body

Dipl.-Ing. M. Adrian