

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	Iskraemeco Savska loka 4 4000 Kranj Slovenia
Measuring instrument	A static Active Electrical Energy Meter Type : MT371, MT372 or MT375 Reference voltage : 3 x 230/400 V Reference current : 5 or 10 A (direct connected) 5 A (indirect connected) Destined for the measurement of : electrical energy, in a - three-phase four-wire network Accuracy class : A or B Environment classes : M1 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes - Description T10118 revision 4 - Documentation folder T10118-3
Valid until	5 March 2018
Remarks	This revision replaces the earlier versions, including its documentation folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
13 July 2011


C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
applicant shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at [http://
ec.europa.eu/enterprise/newapproach/nando/](http://ec.europa.eu/enterprise/newapproach/nando/)

Parties concerned can lodge
objection against this decision,
within six weeks after the date of
submission, to the general manager
of NMi (see www.nmi.nl).

Reproduction of the complete
document only is permitted.